

Monthly Bacteria Testing

PIPE #	Date Collected	Total Coliform	E.coli	Address	Total Coliform	E.coli	chlorine	Results are in parts per million MPN/100 mL	Driven Pipes i
	1/5/2022			514 Miners St	<1.0	<1.0	0.6	low point in system, special test due to pressure loss	
	1/5/2022			105 Main St.	<1.0	<1.0	0.7	high point in system, special test due to pressure loss	
	1/7/2022	2	<1.0	118 Main St.	<1.0	<1.0	0.6		
2	2/9/2022	<1.0	<1.0	118 Main St.	<1.0	<1.0	0.33		
3	3/7/2022	<1.0	<1.0	118 Main St.	<1.0	<1.0	0.8		
4	4/4/2022	<1.0	<1.0	118 Main St.	<1.0	<1.0	0.8		
5	5/11/2022	1.0	<1.0	118 Main St.	<1.0	<1.0	0.4		
manifo	7/7/2022	1.0	<1.0	BIG TANK	<1.0	<1.0	0.3	special test for putting big tank temporarily back in service	
	7/26/2022			527 MinersSt.	<1.0	<1.0	0.05	didn't have to do raw water again for July.	
2	8/3/2022	<1.0	<1.0	527 Miners St.	<1.0	<1.0	0.03		
3	9/6/2022	<1.0	<1.0	527 Miners St.	<1.0	<1.0	ND	CL pump broken, ordering a new one	
4	10/4/2022	<1.0	<1.0	118 Main St.	<1.0	<1.0		They checked the spring water for CL not treated!	
5	11/14/2022	<1.0	<1.0	118 Main St.	<1.0	<1.0	0.3		
6	12/9/2022	<1.0	<1.0	118 Main St.	<1.0	<1.0	0.5		