

1 Water Testing schedule and results

Location	Date	Lead	Copper	ug/l		90th percentile = average of two highest sample results (if you have 5 data sets)
100 Main St.	6/2/2020	7.481	45.68			90th percentil Lead 9.5155
118 Main St.	6/2/2020	3.209	71.37			90th persentile Copper 558.62
234 Main St.	6/2/2020	11.55	11.64			
520 Miners St.	6/2/2020	ND	769.1			
363 Main St.	6/2/2020	2.873	348.2			
	All five locations are within acceptable limits					
					3.755	90th percentile Lead
118 Main St	7/21/2023	2.61	80.2		725	90th percentile copper
520 MinersSt	7/21/2023	0.487	ND			
527 Miners St	7/21/2023	4.9	77.2			
363 Main St	7/21/2023	1.16	390			
234 Main St	7/21/2023	1.73	1060			
	All five locations are within acceptable limits					